

**OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER,  
R.W.S&S SUB DIVISION DHARAMGARH**

Letter No. 533

/Dated/ 25.06.25

To

Shri K. Joy Kutty,  
Director,  
El Nissi Mission School,  
Dharamgarh.


Sub - Water Testing Report.

Ref: - Your Application Received on Dt :- 25.06.2025

Sir,

With reference to the cited above, the water testing report of water sample submitted by you to this office is enclosed herewith for your information & necessary action.

Yours faithfully,

  
Executive Engineer  
RWS&S Sub-Division  
Dharamgarh

Executive Engineer  
RWS&S Sub-Division,  
Dharamgarh

  
Principal  
El Nissi Mission School  
Zion Nagar, Dharamgarh-766015  
Kalahandi, Odisha

  
Manager  
El Nissi Mission School  
Zion Nagar, Dharamgarh-766015  
Kalahandi, Odisha

**WATER SAMPLE REPORT OF RWS&S SUB-DIVISIONAL WATER TESTING LABORATORY, DHARAMGARH**

**Block - Dharamgarh**

**G.P - Chhillipa**

Date of Collection:-  
DT.25.06.2025

Date of Testing :-  
DT.25.06.2025

Name of the Habitation / Location	Source	Portential Hydrogen (pH)	Fluoride (F)	Chloride (Cl)	Hardness (H)	Total Alkallinity (as CaCo3)	Calcium (as Ca)	Magnesium (as Mg)	TDS	Conductivity	Acceptable Limit
EL Nissi Mission School	T/W	7.51	0.67	44	324	348	41.6832	53.46	594.6	915	pH - (6.5-8.5)pH, F-(1.00-1.5)mg/Ltr H-(200-600)mg/Ltr Cl- (250-1000)mg/Ltr TDS-(500-2000)mg/Ltr Alkallinity-(200-600)mg/Ltr Calcium-(75-200)mg/Ltr Magnesium -(30-100)mg/Ltr

*K. Singh*  
25.06.25

*Prasanna Kumar*

**Lab Chemist**  
RWS&S Sub-Division  
Water testing Laboratory  
**Dharamgarh**  
**RWS&S Sub-Divisional**  
**Water Testing Laboratory**  
**Dharamgarh**

**Executive Engineer**  
RWS&S Sub-Division  
**Dharamgarh**

*Prasanna Kumar*

**Principal**  
Einissi Mission School  
Zion Nagar, Dharamgarh-766015  
Kalahandi, Odisha

**Manager**  
Einissi Mission School  
Zion Nagar, Dharamgarh-766015  
Kalahandi, Odisha